

PURCHASE REQUEST CHECK APPROVAL

ITEM DESCRIPTION

[Download PDF! \(http://192.168.1.28/download_PR/1021017446\)](http://192.168.1.28/download_PR/1021017446)

PR Number : 1021017446

Total Price : IDR 2,500,000

Attachment : [Click here \(http://192.168.1.28/assets/lampiranpr/PR_1021017446.JPG\)](http://192.168.1.28/assets/lampiranpr/PR_1021017446.JPG)

Details PR

No.	Item	A	Material	Short Text	Quantity	Unit	Delivery Date	Plant	Matl.Group	PGR	Value
1	10	K		Rewinding Motor Air Blower 1.5 Kw	1.000	PC	22.07.2026	PT SLCI	Supplies	DBA	2,500,000

Purpose:

[10] Additional Job for Rewinding Motor 1.5 kW

GL: 521101

CC: 2011-11060

Dibuat Oleh, 90723(Nurvandy) 2026-06-17 14:47:03	Checked by, 90031(Sigit Setiyono) Approved at 2026-06-17 15:44:15	Budget Control, 90705(Mohamad Rizky) Approved at 2026-06-17 15:53:25	Approved by, 90006(Atikom Imsap) Approved at 2026-06-17 17:02:41
---	--	---	---



PT. Omega Karyatama Elektronindo

Service & Supplier Technical Tools – Electrical – Mechanical – Electric
Motor/Dynamo – Transformer etc.

Telp : 0251-8396564/087893179603

Jl. Raden Koyong Tanah Baru No. 192 RT.002/004 Tanah Baru, North Bogor,
Bogor, West Java

No : 3947/Oke-1/VI/2026

Bogor, 10 Juni 2026

Kepada Yth;
PT. SCG Lightweight Concrete Indonesia
Bpk. Yoki
di tempat

Bersama ini kami mengajukan penawaran harga dengan rincian sebagai berikut :

No.	Nama Barang	Jenis Perbaikan	Qty	Unit Price	Price
1.	Additional Penawaran for Motor 5.5 kW (No. Penawaran : 3796/Oke-1/IV/2026)	-Repair Bearing Housing DE & NDE	2 Pcs	Rp 369,101	Rp 738,202
		-Repair Journal DE + Recenter Shaft	1 Pcs	Rp 376,597	Rp 376,597
		-Repair Journal NDE + Recenter Shaft	1 Pcs	Rp 376,597	Rp 376,597
		-Add New Fan Cover	1 Pcs	Rp 335,000	Rp 335,000
SubTotal :					Rp 1,826,396

Remarks

- Harga Sebelum PPN
- Term of Payment : 30 hari.
- Varnish Class H sistem pengeringan Dry Air.
- Kawat High temperature ~180° C untuk kelas H.
- Slot Insulation : Nomex Paper/Mika Film.
- Kertas Presspan (Asbes & Cevlar Alloy) tahan panas ~180° C.
- Garansi 6 bulan setelah unit diterima perusahaan.
- Garansi berlaku apabila ada kerusakan pada gulungan bukan karena salah pemasangan, beban yang berlebih, kegagalan pada fungsi breaker/contactor, human error, water leakage, kegagalan mekanikal dan lemahnya standar perawatan berkala motor (mis.tidak adanya penggantian bearing secara berkala).
- Apabila setelah dilakukan dismantling dan pengecekan terhadap pekerjaan dan atau penggantian parts diluar dari yang kami tawarkan maka akan kami laporkan dan akan kami tuangkan dalam bentuk kerja tambah (addendum) yang merupakan satu kesatuan dengan penawaran ini.
- Fasilitas antar jemput barang yang diservice.
- Tali pengikat : Nylon rope

Demikian penawaran harga ini kami buat untuk menjadi pertimbangan bapak/ Ibu.
Atas perhatian dan kerjasamanya kami ucapkan terima kasih.

Hormat kami,









PT. Omega Karyatama Elektronik

"One stop solution for your electric motors rewinding & services."
0251-8396564

BEFORE

Additional Penawaran for Motor 5.5 kW (No. Penawaran : 3796/Oke-1/IV/2026)

		
Winding Condition (Burnt)	Bearing Housing Condition (Out of Tolerance) {+0.030}	Bearing Condition (Broken)
		
Shaft Condition (Out of Tolerance) (-0.005)		Without Fan Cover