ROOT CAUSE ANALYSIS			
MACHINE	Frequency	Duration (min)	When
Pressure Drop Compressor saat trial autodrain	1	17.11	Agustus
Downtime Mixing (Mold tidak bisa sirkulasi)  Pressure Drop Alarm WKB [Air Compressed Missing]  Autodrain tidak bekerja  Frequency dan Timer  Solenoid Valve Bocor  Electrical Failure (Rela Contactor, Controller)			